

Environmental Protection Licence Monitoring Data

Project name:	WestConnex – New M5	
Licensee	CPB Contractors Pty Limited	
Monitoring period	September 2016	
Website:	WestConnex – Explore the Route – New M5 (Beverly Hills to St Peters) – New M5 Resources	
Environmental Protection licence number/s:	20772	4627
Premise addresses	WestConnex New M5, between Beverly Hills and St Peters, Beverly Hills NSW 2209	New M5 St Peters Interchange, 10-16 Albert Street, St Peters NSW 2044

Monitoring Type: Water Discharge Monitoring

Discharge/Monitoring Point	Date sampled	Total suspended solids		pH		Oil & Grease		Monitoring frequency	Comment
		Licence limit	Result	Licence limit	Result	Licence limit	Result		
Water Treatment Plant ARN-1	1/09/2016	50	31	6.5-8.5	8.4	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-1	5/09/2016	50	40	6.5-8.5	8.2	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-1	7/09/2016	50	20	6.5-8.5	6.9	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-1	10/09/2016	50	21	6.5-8.5	7.1	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-1	12/09/2016	50	19	6.5-8.5	7.9	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-1	13/09/2016	50	15	6.5-8.5	7.4	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-1	16/09/2016	50	10	6.5-8.5	7	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-1	19/09/2016	50	6	6.5-8.5	6.8	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-1	21/09/2016	50	12	6.5-8.5	7.4	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-1	23/09/2016	50	<5	6.5-8.5	7.2	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-1	24/09/2016	50	16	6.5-8.5	7.9	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-1	26/09/2016	50	18	6.5-8.5	6.8	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-1	29/09/2016	50	9	6.5-8.5	7.9	None visible	None	Each discharge	Compliant
Water Treatment Plant ARN-1	30/09/2016	50	46	6.5-8.5	6.9	None visible	None	Each discharge	Compliant