

### Environmental Protection Licence Monitoring Data

**Project Name:** WestConnex - M8  
**Licensee:** WCX M5 PT PTY LTD  
**Monitoring Period:** 1/1/2021 - 31/1/2021  
**Website:** [www.westconnex.com.au/NewM5Environment](http://www.westconnex.com.au/NewM5Environment)  
**Environmental Protection Licence:** 21351  
**Premise Address:** Operational Water Treatment Plant M8 - Motorway Operations Complex 3 Arncliffe NSW 2205



Monitoring Type:

Sample Date		Discharge/Monitoring Point										Sampling Method							
18 January 2021		Water Treatment Plant ARN-2										Grab Sample							
General				Metals (µg/L)										Total Recoverable Hydrocarbons					
pH		Turbidity (NTU)		Aluminium		Cobalt		Copper		Manganese		Zinc		C10-C16		C16-C34		C34-C40	
Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Results	Limit*	Results
6.5 - 8.5	7.03	25	7	600	40	8.0	1.0	10.3	1.0	10600	1280	150	9	<100	1540	<100	<100	<100	<100

**Key**

\*90th Percentile concentration limit