

Project Name: WestConnex - M4-M8 LINK
Licensee: WCX M4-M5 PT PTY LTD
Monitoring Period: 01/09/2024 - 30/09/2024
Website: www.westconnex.com.au/environment/environmental-documents
Environmental Protection Licence: 21616
Premise Address: ST PETERS INTERCHANGE - M4-M5 LINK TUNNELS PROJECT, 16 ALBERT ST, ST PETERS NSW 2044



Sample Date	Discharge/Monitoring Point	Sampling Method
3/9/2024, 13/9/24, 26/9/24	Water Treatment Plant ARN-2	Grab Sample

General				Metals (mg/L)												Hydrocarbon (mg/L)		Nutrients (mg/L)		Compliant				
pH		Turbidity (NTU)		Cadmium		Chromium (VI)		Iron		Lead		Manganese		Mercury		Nickel		Zinc		Benzene		Ammonia		YES/NO
Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	
3/09/2024	7.53	0.3		<0.0001	0.005			<0.05		<0.001	0.006			<0.00004	0.003	0.009			<0.001			0.94	No (Ammonia)	
13/09/2024	-	-		-	-	0.006		-		0.0044	-	1.90	-	-	-	-			-			0.13	Yes	
20/09/2024	7.39	0.2		<0.0001	0.003			<0.05		<0.001	0.003			<0.00004	0.002	<0.005			<0.001			1.2	No (Ammonia)	
26/09/2024	-	0.2		<0.0001	0.003			<0.05		<0.001	0.003			<0.00004	0.002	<0.005			<0.001			1.44	No (Ammonia)	

* 100th percentile concentration limit
 Note: Daily discharge data was unavailable at time of publishing. This report will be reissued when data is made available.