EPL 21616

Link WTP Monthly Results

							General Field Tested		General Lab Tested	Metals (Dissolved)									Nutrients	Hydrocarbons
							pH	Turbidity	Turbidity	Cadmium	Chromium	Chromium (VI)*	Iron	Lead	Manganese	Nickel	Zinc	Mercury	Ammonia	Benzene
						Prefix				Ca	Cr	Cr^{6+}	Fe	Pb	Mn	Ni	Zn	Hg	NH_3	
						Unit	pH Units	NTU	NTU	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
						EPA 100th Percentile Limit	7-8.5	10	10	0.0007		0.0060	0.3000	0.0044	1.9	0.07	0.015	0.0001	0.91	0.5
						LAB Test LOR (ALS)			<0.1	0.0001	0.001	0.001	0.05	0.001	0.001	0.001	0.005	0.00004	0.01	0.001
	M4-M8 Link Water Treatment Plant						**M4-M8 Link Water Treatment Plant**													
2024	10/01/2024	ES2400726	Outlet	ALS	9:43	Clear, no odour	7.31	0.10	0.1	0.0001	0.001	0.004	0.05	0.001	0.001	0.001	0.005	0.00004	0.44	0.001
	10/01/2024	341193	Outlet	Envirolab	9:43	Clear, no odour	7.31	0.10	0.2	0.0001	0.005	0.004	0.12	0.001	0.005	0.002	0.002	0.00005	0.34	0.001
	7/02/2024	ES2403908	Outlet	ALS	9:43	Clear, no odour	7.32	0.01	0.1	0.0001	0.004	0.004	0.05	0.001	0.001	0.002	0.005	0.00004	0.44	0.001
	5/03/2024	ES2407167	Outlet	ALS	9:57	Clear, no odour	7.42	0.01	0.1	0.0001	0.004	0.006	0.05	0.001	0.003	0.001	0.005	0.00004	0.02	0.001
	23/04/2024	ES2413226	Outlet	ALS	8:30	clear, no odour	7.55	0.01	0.2	0.0001	0.006	0.006	0.05	0.001	0.001	0.040	0.023	0.00004	0.09	0.001
	3/05/2024	ES2414410	Outlet	ALS	12:02	NA	7.20	0.01	0.3	0.0001	0.006	0.005	0.05	0.001	0.004	0.002	0.005	0.00004	1.10	0.001
	16/05/2024	ES2416099	Outlet	ALS	-	NA													0.89	
	5/06/2024	ES2418490	Outlet	ALS	9:49	NA	7.56	0.01	0.1	0.0001	0.005	0.006	0.05	0.001	0.003	0.002	0.005	0.00004	0.02	0.001
	4/07/2024	ES2422242	Outlet	ALS	8:23	NA	7.71	1.57	0.1	0.0001	0.003	0.002	0.05	0.001	0.004	0.004	0.005	0.00004	0.07	0.001
	29/07/2024	ES2424992	Outlet	ALS	14:25	NA													0.05	
	1/08/2024	ES2425177	Outlet	ALS	15:25	NA	7.53	9.99	0.2	0.0001	0.004	0.005	0.05	0.001	0.001	0.001	0.005	0.00004	0.01	0.001
	19/08/2024	ES2427153	Outlet	ALS	14:35	NA													0.01	

* By discrete analyser low level