

Environmental Protection Licence Monitoring Data



Project Name: WestConnex - M8
Licensee: WCX M5 PT PTY LTD
Monitoring Period: 1/04/2022 - 30/04/2022
Website: www.westconnex.com.au/NewM5Environment
Environmental Protection Licence: 21351
Premise Address: Operational Water Treatment Plant M8 - Motorway Operations Complex 3 Arncliffe NSW 2205

Monitoring Type:

Sample Date	Discharge/Monitoring Point	Sampling Method
20 April 2022	Water Treatment Plant ARN-2	Grab Sample

General				Metals (µg/L)										Total Recoverable Hydrocarbons					
pH		Turbidity (NTU)		Aluminium		Cobalt		Copper		Manganese		Zinc		C10-C16		C16-C34		C34-C40	
Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Results	Limit*	Results
6.5 - 8.5	7.89	25	7.1	600	100	8.0	2.0	10.3	<1.0	10600	1070	150	<5	<100	<100	<100	<100	<100	<100

Key

*90th Percentile concentration limit